

RULE 62. SULFUR CONTENT OF FUELS (Effective 7/14/70:
Rev. Effective 10/21/81)

(a) **APPLICABILITY**

This rule is applicable to all stationary fuel burning equipment except as provided for by Rule 53.1, and except for the combustion of sewage treatment plant digester gases and the incineration of gases emitted from solid waste disposal landfill sites. (Rev. Effective 10/21/81)

(b) **STANDARD**

A person shall not operate any stationary fuel-burning equipment subject to this rule unless:

- (1) Any gaseous fuel used contains no more than 10 grains of sulfur compounds, calculated as hydrogen sulfide, per 100 cubic feet of dry gaseous fuel (0.23 grams of sulfur compounds, calculated as hydrogen sulfide, per cubic meter of dry gaseous fuel), at standard conditions.
- (2) Any liquid or solid fuel used contains no more than 0.5 percent sulfur by weight, or
- (3) The equipment can be so operated as to achieve equivalent results, documented by the person by stack test to the satisfaction of the Air Pollution Control Officer.

RULE 62.1 NSPS REQUIREMENTS FOR SULFUR CONTENT OF FUELS
(Effective 11/8/76)

A person owning or operating any source subject to the provisions of any federal New Source Performance Standard (NSPS) which has been delegated to the Air Pollution Control District of San Diego County, must in addition to complying with Rule 62, comply with Regulation X.